

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3175-1317:103 Page 1 of 1

CATEGORY: Air Filter Units

LISTEE: Purolator, PO Box 1637, Henderson NC 27536
Contact Person: David Brooks (252) 492-1141

DESIGN: Air filter units Models "**Serva-pak 65, 85 or 95, followed by -C1 or -C2, with 22", 30" or 36" length; Model Serva-pak 50, followed by -C1 or -C2, with 10", 15", 18" or 22" length; and Model Serva-pak 40G-C2, with 12" or 22" length. These filter are dry-type, extended area and replaceable media. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Serva-pak 50, 65, 85 or 95: Class I or Class II
Serva-pak 40G: Class II

INSULATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, size, rating and UL label.

APPROVAL: Listed as Class I or Class II dry-type air filter units.

NOTE: Formerly 3175-0481:004

*Rev. 07-26-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 5, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager